

**BUILDING SAFETY CERTIFICATE**No. 04/NBC/25-26Dated: 01/05/25

Certified that the existing building **S R MEMORIAL INTERNATIONAL SCHOOL, ADDA USARA, ETAWAH U.P.** comprised of GROUND FLOOR, FIRST FLOOR AND SECOND FLOOR owned/occupied by **S R MEMORIAL INTERNATIONAL SCHOOL, ETAWAH** have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of UPPWD on 01/05/25 in the presence of Mr. Umakant Yadav, **S R MEMORIAL INTERNATIONAL SCHOOL, ADDA USARA, ETAWAH U.P.** and that the building/premises is fit for occupancy upto classes PG to XII (X/XII) with effect from 01/05/25 For a period of 03 in accordance with rule and subject to compliance of the specific conditions as appended.

1. Two doors in every class room with a size of wide 1.20 m & height 2.40 m minimum.
2. Fire Safety System working properly.
3. Minimum height of first floor terrace is 3.60 meter.
4. Teacher give training for students about fire protection.


Issued on 01/05/25 at by.

Signature with Seal:

Name: Gaurav Jain

Designation: Assistant Engineer

Name &amp; Address of Department/Office: U.P. PWD

  
01/05/25  
 सहायक अभियन्ता  
 विभाग खण्ड-1, लोअरमिडियम  
 इटावा