

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 016/2025

Dated: 21.04.2025

It is certified that an inspection team headed by Mr. Shivam Kumar Verma

(Name of Officers with designation) from Quality Manager/Technical Officer PHED

inspected the S R Memorial International School, Baudh Nagar, Adda Usara, Etawah

(Name & Address of the school) on 19.04.2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. TC-12223 dated 19.04.2025

of District Level Water Analysis Laboratory (PHED Lab) certified that the

S R Memorial International School, Etawah (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 2025-26.

Signature with Seal:

Name

Designation

Name & Address of the Office / Department

Mr. Shivam Kumar Verma

Quality Manager/Technical Officer

UP

Jal Nigam, Etawah

To The Principal

S R Memorial International School, Baudh Nagar, Adda Usara, Etawah

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies





District Level Water Analysis Laboratory of Uttar Pradesh Jal Nigam (Rural) Etawah



TC-12223

Analysis Water Test Report

ULR No.	TC-12223-2500000000001F	Chemical Test/01	Date: 21/04/2025	Page No.	1
Customer Details					
Office Name & Address	School S.R Memorial International School, Buddh Nagar, Adda Usra Etawah				
Ref. Letter No. & Date	SRMIS /Etawah/007/2025				
Basic Details of Sample					
District	Etawah	Block	Badpura		
Gram Panchayat	-	Village	-		
Habitation	-	Location	Near By Bharat Gas Godam		
Water Source	Submersible	Sample code	ETW/25/04/1P (260P)		
Quantity of Sample	2 Liter	Date of S.C	17/04/2025		
Receiving Date	17/04/2025	S. Collector	Rajesh Kumar		
Sample Depositor	Rajesh Kumar	Analysis Completion Date	19/04/2025		
Analysis Start Date	17 /04/2025				
Environmental Condition					
Temperature	25±3°C	Humidity	50±15%		
Technical Data of Analysis					
S. No.	Analyzed Parameters	Observed Value	Specified Values as per BIS 10500:2012		Ref. Method of Analysis
			Acceptable Limit	Permissible	
1	Odour	Agreeable	Agreeable	Agreeable/Not Agreeable	IS3025(Part 5): 2023
2	Taste	Agreeable	Agreeable	Agreeable/Not Agreeable	IS3025 (Part 7): 2023
3	Colour	05	5	15	IS3025(Part -4):2021
4	Turbidity (NTU)	1.25	1	5	IS3025(Part-10):2023 (Nephelometric method)
5	PH	7.71	6.5	8.5	IS3025(Part11):2022 (Electrometric Method)
6	TDS (Mg/L)	95	500	2000	IS3025 (Part 16):2023 (Gravimetric Method)
7	Alkalinity (Mg/L)	60	200	600	IS3025(Part-23): 2023 (indicator Method)
8	Total Hardness (Mg/L)	90	200	600	IS3025(Part-21): 2019 (EDTA)
9	Sulphate (Mg/L)	23.53	200	400	IS3025(Part-24):2022
10	Nitrate (Mg/L)	2.67	45	No Relaxation	APHA Method 24 rd Addition 4500 : 2023
11	Iron (Mg/L)	0.38	0.3	1.0	IS3025 (Part-53) : 2024(1,10 Phenanthroline Method)
12	Chloride (Mg/L)	45	250	1000	IS3025(Part-32): 2019
13	Magnesium	4.8	30	100	IS3025(Part-46):2023
14	Calcium	28.05	75	200	IS3025(Part-40):2023
15	Fluoride (Mg/L)	0.5	1.0	1.5	IS3025 (Part-60) :2008 (Electro Chemical Prob. Method)
Note:-					
1- This Certificate refers only to the particular sample (s) submitted for testing.					
2- This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory					
3- The test result reported in this certificate are valid at the time of and under the stated conditions of measurements.					
4- Sample will be stored up to 7 days (in case of non-perishable items only) from the date of issue of test reports unless otherwise specified.					
5- Parameters above permissible limit are written in Bold.					
Report Prepared By DQM/DTM Pradeep Kumar					
Authorized Signatory (Shivam Kumar Verma) Quality Manager/Technical Manager Mob-8126544535					
Laboratory Contact Details Email-etawahlab@gmail.com					

End of Report



**District Level Water Analysis Laboratory of
Uttar Pradesh Jal Nigam (Rural) Etawah.**

Issue No. :

Issue Date-21/04/2025



Report No/Sample Code	Bacteria Test/ ETW/25/04/1P (260P)	District	Etawah
Office Name & Address	School S.R Memorial International School, Buddh Nagar, Adda Usra Etawah	Block	Badpura
Gram Panchayat	-	Village	-
Habitation	-	Location	Near By Bharat Gas Godam
Water Source	Submersible	Sample No	1
Quantity of Sample	500 ml	Date Of Collection	17/04/2025
Receiving Date	17/04/2025	Sample Collector	Rajesh Kumar
Sample Depositor	Rajesh Kumar	Sampling Method	-
Analysis Start Date	17/04/2025	Analysis Completion	19/04/2025
Temperature	25±3°C	Humidity	50±15%

Technical Data Of Analysis

Sr.No.	Analysed Parameter	Observed Value	Specified Values as Per BIS 10500:2012		Ref. Method of analysis
			Acceptable Limit	Permissible Limit	
1.	pH	7.71	6.5-8.5	No relaxation	IS 3025(Part-11)2022
2.	Residual Chlorine (mg/l)	0.2	0.20	1.00	IS 3025(Part-26)2022
3.	Total Coliform (CFU)	00	No relaxation	No relaxation	IS 15185:2016
4.	E .Coli (CFU)	00	No relaxation	No relaxation	IS 15185:2016

Note:

1. This certificate refers only to the particular sample submitted for testing.
2. This certificate shall not be reproduced, except in full unless written permission of an approved has been Obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample Will be Stored up to 07 days (in case of non -perishable items only) from the date of issue.



End of Report